

New ISO 9060:2018 Pyranometer Classifications

Apogee Instruments Pyranometers Meet New Class C Standard

With the release of the new ISO-9060:2018 pyranometer classifications, ISO did away with the old, confusing standards and has now grouped all pyranometers into three new categories: A, B, and C. With this, Apogee's pyranometers are all ranked in the C Classification, but not all C Class pyranometers are created equal. For example, the Apogee SP-510 thermopile sensor is only negligibly different than a Class B. The ISO standards are listed below, along with the Apogee pyranometer specifications.

ISO 9060:2018(E) Pyranometer Classification List				Apogee Models		
	Parameter	A (Secondary standard)	B (First class)	C (Second class)	Apogee SP-510 Thermopile	Apogee SP-110 Silicon-cell
A	Response time	< 10 s	< 20 s	< 30 s	0.5 s*	< 0.001 s*
B	Zero offset A	$\pm 7 \text{ W/m}^2$	$\pm 15 \text{ W/m}^2$	$\pm 30 \text{ W/m}^2$	$\pm 8 \text{ W/m}^2$; $\pm 30 \text{ W/m}^2$ (heated)	N/A
B	Zero offset B	$\pm 2 \text{ W/m}^2$	$\pm 4 \text{ W/m}^2$	$\pm 8 \text{ W/m}^2$	$\pm 5 \text{ W/m}^2$	N/A
B	Zero offset C	$\pm 10 \text{ W/m}^2$	$\pm 21 \text{ W/m}^2$	41 W/m^2	$\pm 13 \text{ W/m}^2$; $\pm 35 \text{ W/m}^2$ (heated)	N/A
C1	Non-stability	$\pm 0.8 \%$	$\pm 1.5 \%$	$\pm 3 \%$	$\pm 2 \%$	$\pm 2 \%$
C2	Nonlinearity	$\pm 0.5 \%$	$\pm 1 \%$	$\pm 3 \%$	$\pm 1 \%$	$\pm 1 \%$
C3	Directional response	$\pm 10 \text{ W/m}^2$	$\pm 20 \text{ W/m}^2$	$\pm 30 \text{ W/m}^2$	$\pm 25 \text{ W/m}^2$	$\pm 30 \text{ W/m}^2$
C4	Spectral error	$\pm 0.5 \%$	$\pm 1 \%$	$\pm 5 \%$	$\pm 2 \%$	$\pm 4 \%$
C5	Temperature response	$\pm 1 \%$	$\pm 2 \%$	$\pm 4 \%$	$\pm 4 \%$	$\pm 3 \%$
C6	Tilt response	$\pm 0.5 \%$	$\pm 2 \%$	$\pm 5 \%$	$\pm 1 \%$	N/A
C7	Additional signal processing errors	$\pm 2 \text{ W/m}^2$	$\pm 5 \text{ W/m}^2$	$\pm 10 \text{ W/m}^2$	N/A	N/A

* Pyranometers with response times < 0.5 seconds are classified as "fast response" pyranometers.


SP-510 thermopile




SP-110 silicon-cell



- **Response time:** time for 95 % response
- **Zero offset A:** response to -200 W/m^2 net thermal radiation
- **Zero offset B:** response to 5° C per hour change in ambient temperature
- **Zero offset C:** total zero offset including zero offset A, zero offset B, and other sources
- **Non-stability:** percentage change in responsivity per year
- **Nonlinearity:** percentage deviation from the responsivity at 500 W/m^2 due to the change in irradiance within 100 W/m^2 to 1000 W/m^2
- **Directional response** (for beam radiation): the range of errors caused by assuming that the normal incidence responsivity is valid for all directions when measuring from any direction (with an incidence angle of up to 90° or even from below the sensor) a beam radiation whose normal incidence irradiance is 1000 W/m^2
- **Spectral error:** maximum spectral error observed for a set of global horizontal irradiance clear sky spectra defined in the ISO 9060:2018(E) document
- **Temperature response:** percentage deviation due to the change in ambient temperature within the interval from -10° C to 40° C relative to the signal at 20° C
- **Tilt response:** percentage deviation from the responsivity at 0° tilt (horizontal) due to change in tilt from 0° to 180° at 1000 W/m^2 irradiance



Differences [%] of an **SP-510 thermopile** pyranometer and an **SP-110 silicon-cell** from the mean of the four secondary standard (reference) pyranometers as a function of cloudiness. The variable SW_i / SW_{ic} is the ratio of measured global shortwave irradiance [W m^{-2}] to clear sky global shortwave irradiance [W m^{-2}] calculated from a model, and serves as a cloudiness index. Values of SW_i / SW_{ic} near one indicate clear sky and values near zero indicate overcast sky. The predicted error values listed on each graph were calculated from the spectral response for each sensor and a solar spectrum for overcast conditions, assuming the pyranometers were calibrated under clear sky conditions.



Differences [%] of an **SP-510 thermopile** from the mean of four secondary standard (reference) pyranometers as a function of solar zenith angle. Black lines are bin averages for AM and PM. The green and orange lines are estimates of the specifications for first class ($\pm 20 \text{ W m}^{-2}$) and second class ($\pm 30 \text{ W m}^{-2}$) pyranometers, respectively, as a function of solar zenith angle.